

**§ 149.407**

type under 46 CFR part 162, subparts 162.028 and 162.039, respectively.

**§ 149.407 Must fire extinguishers be on the deepwater port at all times?**

(a) The fire extinguishers required by §149.409 of this part must be on all manned deepwater ports at all times.

(b) The fire extinguishers required by §149.409 of this part need be on unmanned deepwater ports only when personnel are working on the deepwater port during cargo transfer operations, or performing maintenance duties.

[USCG-1998-3884, 71 FR 57651, Sept. 29, 2006, as amended by USCG-2013-0397, 78 FR 39179, July 1, 2013]

**33 CFR Ch. I (7-1-13 Edition)**

**§ 149.408 What are the maintenance requirements for fire extinguishers?**

All fire extinguishers must be maintained in good working order and serviced annually in accordance with 46 CFR 107.235.

**§ 149.409 How many fire extinguishers are needed?**

Each particular location must have the number of fire extinguishers required by Table 149.409 of this section.

**TABLE 149.409—PORTABLE AND SEMI-PORTABLE EXTINGUISHERS, MINIMUM QUANTITY AND LOCATION**

Space	Classification	Minimum quantity and location
(a) Safety Areas:		
(1) Communicating corridors.	A-II .....	One in each main corridor or stairway not more than 150 feet apart.
(2) Radio room .....	C-II .....	One outside or near each radio room exit.
(b) Accommodation Spaces:		
(1) Sleeping quarters .....	A-II .....	One in each sleeping space that fits more than four persons.
(c) Service Spaces:		
(1) Galleys .....	B-II or CII .....	One for each 2,500 square feet or fraction thereof, for hazards involved.
(2) Storerooms .....	A-II .....	One for each 2,500 square feet or fraction thereof, located near each exit, either inside or outside the space.
(3) Paint room .....	B-II .....	One outside each paint room exit.
(d) Machinery Spaces:		
(1) Gas-fired boilers .....	B-II OR C-II .....	Two.
(2) Gas-fired boilers .....	B-V .....	One. <sup>1</sup>
(3) Oil-fired boilers .....	B-II .....	Two.
(4) Oil-fired boilers .....	B-V .....	Two. <sup>1</sup>
(5) Internal combustion or gas turbine engines.	B-II .....	One for each engine. <sup>2</sup>
(6) Open electric motors and generators.	C-II .....	One for each of two motors or generators. <sup>3</sup>
(e) Helicopter Areas:		
(1) Helicopter landing decks.	B-V .....	One at each access route.
(2) Helicopter fueling facility.	B-V .....	One at each fuel transfer facility. <sup>4</sup>

<sup>1</sup> Not required if a fixed system is installed.

<sup>2</sup> If the engine is installed on a weather deck or is open to the atmosphere at all times, one B-II may be used for every three engines.

<sup>3</sup> Small electrical appliances, such as fans, are exempt.

<sup>4</sup> Not required if a fixed foam system is installed in accordance with 46 CFR 108.489.

[USCG-1998-3884, 71 FR 57651, Sept. 29, 2006, as amended by USCG-2013-0397, 78 FR 39179, July 1, 2013]

**§ 149.410 Where must portable and semi-portable fire extinguishers be located?**

All portable and semi-portable fire extinguishers described in Table 149.409

of this part must be located in the open so as to be readily seen.

[USCG-1998-3884, 71 FR 57651, Sept. 29, 2006, as amended by USCG-2013-0397, 78 FR 39179, July 1, 2013]

**§ 149.411 What are the requirements for firemen's outfits?**

(a) Each manned deepwater port with nine or more persons must have at